



Worcester County Administration Office
1 West Market Street, Room 1103
Snow Hill, MD 21863
Ph. 410-632-1194 Fax 410-632-3131
Email: nrice@co.worcester.md.us

Addendum # 1 Roofing Work at the Library Annex in Snow Hill

Date of Addendum: 8/18/23

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – CLARIFICATIONS

The following clarifications are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Description
1.1	Color chosen is Shakedown from the GAF Timberline HDZ shingle line

2.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
2.1	Q. T & M Rate sheet under separate cover? A. Yes
2.2	Q. Can the soffit be replaced with vinyl soffit? A. Yes
2.3	Q. Is the replacement for Gutter/Downspout to be; 6” gutters and 3 x 4 downspouts? A. The idea was to replace existing with same as there were no problems with gutter drainage. The gutters appear to be 5” and downspouts 3x4”. Ultimately it is the contractor’s responsibility to confirm existing conditions.

END OF ADDENDUM