



Worcester County Administration Office  
 1 West Market Street, Room 1103  
 Snow Hill, MD 21863  
 Ph. 410-632-1194 Fax 410-632-3131  
 Email: [nrice@co.worcester.md.us](mailto:nrice@co.worcester.md.us)

## Addendum # 1 Commission on Aging Parking Lot Expansion

Date of Addendum: 3/28/25

<b>NOTICE TO ALL BIDDERS AND PLANHOLDERS</b>
<p>The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.</p>

<b>BID SUBMITTAL DEADLINE</b>
<p>The bid submittal time has not been changed.</p>

<b>1.0 – ATTACHMENTS</b>	
<b>Item</b>	<b>Description</b>
1.1	Revised Form of Bid – to be used in lieu of the Form of Bid provided in the original Bid Documents

<b>2.0 – QUESTIONS AND ANSWERS</b>	
<p>The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.</p>	
<b>Item</b>	<b>Questions and Answers</b>
2.1	<p>Q. Item C.1, under the Summary, states that the bid will include 12 to 14 new spaces, and also requests alternate pricing for an entrance/exit connection to the service road. Will the number of new spaces be 12 or 14? Also, under the base bid, will the new spaces end in the same configuration as the existing parking lot, with a stub for connecting to the future entrance/exit?</p> <p>A. There will be 14 new spaces. Yes, if the alternate pricing of the connection driveway is not accepted, the parking area will end in the same configuration.</p>
2.2	<p>Q. Item C. 7, under the Summary, lists a quantity of 4,200 SY, and further calls for all striping, directional arrows, and stop bars. This would indicate that the existing paved areas are to be repaved. Is this correct? If so, will the repaving be at 1-1/2" depth?</p> <p>A. Paving is to occur in the new section(s) only. No additional areas are to be resurfaced. However, all striping, arrows and stop bars in the existing section of the lot are to be repainted as well as in the new section(s).</p>
2.3	<p>Q. The Form of Bid does not include an item for the alternate pricing as called out in Item C.1. Please clarify.</p> <p>A. Please see the attached Revised Form of Bid.</p>

**END OF ADDENDUM**

## REVISED - FORM OF BID

To whom it may concern:

We hereby submit our Bid Documents for “COMMISSION ON AGING PARKING LOT EXPANSION” as indicated in the Bid Documents. Having carefully examined the Bid Documents and having received clarification on all items of conflict or upon which any doubt arose, the undersigned hereby requests consideration of our Vendor for award of the referenced Bid.

ITEM	DESCRIPTION	EXTENDED PRICE
1	Provide labor, materials and equipment for the expansion of the Commission on Aging Parking Lot as stated in the Bid Specifications.	

**ALTERNATE**

ITEM	DESCRIPTION	EXTENDED PRICE
1	Concrete Sidewalk and Curbing	
2	Entrance/Exit connection to the service road	

Vendor agrees to have the Work completed within six weeks from the Notice to Proceed. (Yes)\_\_\_\_ (No) \_\_\_\_\_ Check One.

Have you included your certificate of good standing with the State of Maryland? (See Section I, Subsection H.1 for more information.) (Yes)\_\_\_\_ (No) \_\_\_\_\_ Check One.

Is your company currently involved in any active litigation? (Yes)\_\_\_\_ (No) \_\_\_\_\_ Check One.

Is your company currently involved in any mergers or acquisitions? (Yes)\_\_\_\_ (No) \_\_\_\_\_ Check One.

The Vendor agrees that their bid will be good for at least sixty days unless otherwise indicated in the bid specifications.

Note: This bid form must be signed by an officer of your company or an authorized agent for this bid to be considered valid by the county.

\_\_\_\_\_  
Sign for Identification

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Title

\_\_\_\_\_  
Email